

WESTERN ELECTRICITY SUPPLY COMPANY OF
ORISSA
WESCO

VOLUME- II

**(Tender Specification: WESCO/CEO/023)
GROUP-C**

**[Detail Scope of Supply]
ANNEXURE**

Date: 25.10.2011

VOLUME-II DSS	Specification : WESCO/CEO/023, 11-12
---------------	--------------------------------------

**WESTERN ELECTRICITY SUPPLY COMPANY OF
ORISSA
WESCO**

**TENDER DOCUMENT FOR SUPPLY OF
GROUP- C ITEMS**

SPECIFICATION FOR GROUP- C ITEMS

11 KV 'V' Crossarm	Quantity
11 KV 'V' Crossarm made out of 75 x 40 mm M.S. Channel as per REC Standard A6. The crossarm shall be fabricated out of 75 x 40 mm size Channel having 6.8 kg/mtr. with 50 mm x 6 mm flat as per drawing on top & bottom flange of the channel where the Insulator pin is to be mounted. After fabrication the crossarm shall be painted with two coats of Red Oxide primer, conforming to REC construction standard & drawing provided.	383 No

LT Cross arm, 3 ph 4W	Quantity
L.T 3-phase, 4- wire Crossarm made out of 75 mm x 40 mm channel. The crossarm shall be fabricated out of 75 x 40 mm size Channel with 50 mm x 6 mm cleats as per drawing on top & bottom flange of the channel where the Insulator pin is to be mounted, conforming to REC construction standard & GTP provided.	750 nos