

WESTERN ELECTRICITY SUPPLY COMPANY OF
ORISSA
WESCO

VOLUME- II

(Tender Specification: WESCO/CEO/021)
GROUP-AA

[Detail Scope of Supply]
ANNEXURE

Date: 27.09.2008

**WESTERN ELECTRICITY SUPPLY COMPANY OF
ORISSA
WESCO**

**TENDER DOCUMENT FOR
GROUP- AA ITEMS**

SPECIFICATION FOR GROUP-AA ITEMS

RING TYPE LTCT	Quantity
Ring type LTCT , Conforming to IS:2705/1992 having 'Phase to Neutral' 240 volts : CT Ratio : 50/5 A	25 no
Do but CT Ratio : 100/5 A	200 no
Do but CT Ratio : 150/5 A	200 no
Do but CT Ratio : 200/5 A	200 no
Do but CT Ratio : 400/5 A	150 no
Do but CT Ratio : 600/5 A	250 no
Do but CT Ratio : 800/5 A	250 no
Do but CT Ratio : 1200/5 A	10 no
Digital Clamp On Meter/ Tongue Tester: Range:-1000 Amp A.C, LCD Display, Data hold to freeze the displayed value complete with test lids.	30 No

N.B :- Type test certificates from CPRI or accredited NABL laboratory should be furnished for LTCT.