

WESTERN ELECTRICITY SUPPLY COMPANY OF ORISSA
WESCO

VOLUME- II

(Tender Specification: WESCO/CEO/021)
GROUP-S

[Detail Scope of Supply]
ANNEXURE

Date: 27.09.2008

VOLUME-II DSS	Specification : WESCO/CEO/021, 08-09
---------------	--------------------------------------

WESTERN ELECTRICITY SUPPLY COMPANY OF ORISSA
WESCO

TENDER DOCUMENT FOR
GROUP- S ITEMS

SPECIFICATION FOR GROUP-S ITEMS

EARTH DISCHARGE ROD	Quantity
Highly insulated multipurpose telescopic Earth Discharge Rod/Operating Rod made out of Class-I fibre glass and non-conductive resin in four sections, each 4 ft. long approximately suitable for operating voltage upto 33 kv. The weight of each set shall be 3 to 4 kgs. Approximately in weight. Torch light attachment, Tree cutting attachment should be available for operation at night by a single person and with the following materials :- (a) D.O head & rubber grip. (b) Earthing Instrument with wire plug. © A.B Switch ON/OFF Instruments. (d) 20 ft. of 7/20 PVC Copper earth wire. (e) Canvass Tool bag.	500 No

RUBBER HAND GLOVES	Quantity
Highly insulated Rubber Hand Gloves, seamless type, 380 mm long, tested in potential 15000 volts, as per ISS : 4770/1986, 1 st Revision & its relevant latest amendments. N.B : Specification enclosed	1500 Pair

N.B :- Type test certificates from CPRI or accredited NABL laboratory should be furnished.

VOLUME-II DSS	Specification : WESCO/CEO/021, 08-09
---------------	--------------------------------------