

WESTERN ELECTRICITY SUPPLY COMPANY OF ORISSA
WESCO

VOLUME- II

**(Tender Specification: WESCO/CEO/021)
GROUP-AC**

**[Detail Scope of Supply]
ANNEXURE**

Date: 27.09.2008

VOLUME-II DSS	Specification : WESCO/CEO/021, 08-09
---------------	--------------------------------------

WESTERN ELECTRICITY SUPPLY COMPANY OF ORISSA
WESCO

TENDER DOCUMENT FOR
GROUP- AC ITEMS

SPECIFICATION FOR GROUP-AC ITEMS

Sl. No.	Item Description	Qty.
1.	3 phase, 4 wire LTCT Meter with TP Box (Iron Double door), 3x240 volts, Accuracy Class: 0.5, CTR-100/5Amp as per GTP & Drawing.	50 No
2.	3 phase, 4 wire LTCT Meter with TP Box (Iron Double door), 3x240 volts, Accuracy class: 0.5, CTR-200/5Amp as per GTP & Drawing.	50 No
3	3- phase, 4-wire Static H.T Trivector Meter with ABT & TOD features (ultrasonic welding) <u>SPECIFICATIONS :</u> Volts: - /110 Volts, Accuracy Class: 0.2s, Current: -/5 A as per the enclosed GTP	13 No
4	3- phase, 4-wire Static H.T Trivector Meter with ABT & TOD features (ultrasonic welding) <u>SPECIFICATIONS :</u> Volts: - /110 Volts, Accuracy Class: 0.5s, Current: -/5 A as per the enclosed GTP	37 Nos
5.	Static Whole Current Meter, 3-ph, 4 wire : Volts: 240 V, Current: 20-100 A, Accuracy Class: 1.0s with TOD features having Ultrasonic welding & as per GTP. N.B : GTP Enclosed	750 No
6.	TP Boxes for above meters as per technical specification, GTP & drawing. N.B: Technical Specification (Enclosed) GTP (Enclosed) Drawing (Enclosed)	50 No

N.B :- Type test certificates from CPRI or accredited NABL laboratory should be furnished.
Guaranteed Technical Particulars shall be submitted with your offer

WESTERN ELECTRICITY SUPPLY COMPANY OF ORISSA
WESCO
